

Test Verification of Conformity

Verification Number: 241028022GZU-VOC001

On the basis of the tests undertaken, the sample<s> of the below product has been tested by an accredited 3rd party laboratory in accordance to the referenced specification<s>/standard<s> at the time the tests were carried out. This verification is part of the full test report<s> and should be read in conjunction with it <them>.

This document can be used in support of a claim in meeting relevant 2014/30/EU legislation and mandatory Conformity Marking. And in accordance with EU law, the claim is the sole obligation of the Manufacturer/ Importer.

Applicant Name & Address:

Shenzhen Aohai Digital Power Co., Ltd.
2501, Building 1, Huide Building, North Station Community, Minzhi Street, Longhua District, Shenzhen, P.R. China.

Product Description:

Three-Phase Hybrid Inverter

Models/Type References:

AHW-6KTHD-G1, AHW-7KTHD-G1, AHW-8KTHD-G1, AHW-10KTHD-G1

Ratings & Principle

See Appendix

Characteristics:

Brand Names:

AOHAI

Specification<s>/Standards:

EN IEC 61000-6-3:2021
EN IEC 61000-6-1:2019

Verification Issuing Office Name & Address:

Intertek Testing Services Shenzhen Ltd. Guangzhou Branch
Room101/301/401/102/202/302/402/502/602/702/802, No. 7-2, Caipin Road, Huangpu District, Guangzhou, Guangdong, China

Date of Tests:

28 October 2024-09 January 2025

Test Report Number(s):

241028022GZU-001

Additional information in Appendix.



Signature

Name: Sky Zhu

Position: Supervisor

Date: 10 February 2025

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

APPENDIX: Test Verification of Conformity

This is an Appendix to Test Verification of Conformity Number: 241028022GZU-VOC001.

Inverter Module	AHW-6KTHD-G1	AHW-7KTHD-G1	AHW-8KTHD-G1	AHW-10KTHD-G1
PV Input				
Max.PV input voltage	1000Vd.c.			
MPPT voltage range	120~1000Vd.c.			
Max.PV input power	9000W	10500W	12000W	15000W
Max.PV input current	16Ad.c.*2			
Isc PV (absolute maximum)	20Ad.c.*2			
Start-up voltage	120Vd.c.			
Nominal input voltage	600Vd.c.			
Battery				
Battery Type	Li-ion			
Battery voltage range	100~600Vd.c.			
Max.charge/discharge current	25Ad.c./25Ad.c.			
AC Input				
Rated voltage	3L/N/PE 230/400Va.c.			
Max. continuous current	9.1Aa.c.	10.6Aa.c.	12.2Aa.c.	15.2Aa.c.
Rated frequency	50/60Hz			
AC Output (On Grid)				
Rated active power	6000W	7000W	8000W	10000W
Max. apparent power	6000VA	7000VA	8000VA	10000VA
Rated voltage	3L/N/PE 230/400Va.c.			
Max. current	9.1Aa.c.	10.6Aa.c.	12.2Aa.c.	15.2Aa.c.
Frequency	50/60Hz			
Power factor range	0.8 leading to 0.8 lagging			
AC Output (Back-up)				
Max.apparent power	6000VA	7000	8000	10000
Rated voltage	3L/N/PE 230/400Va.c.			
Max.current	9.1Aa.c.	10.6 Aa.c.	12.2 Aa.c.	15.2 Aa.c.
Frequency	50/60Hz			
Power factor range	0.8 leading to 0.8 lagging			
General Information				
Operating temperature range	-25...+60°C			
Inverter topology	Non-isolated			
Ingress protection	IP65			
Protective class	I			
Over voltage category	II(DC),III(MAINS)			

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Software version	CA1.0
------------------	-------



Signature

Name: Sky Zhu

Position: Supervisor

Date: 10 February 2025

This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.